

METHACTON HIGH SCHOOL POOL EVALUATION


FEBRUARY 2023





Natatorium/Pool:

- Natatorium space in need of refurbishing
- Bleachers are elevated and have no ADA access
- Many aquatic elements including the diving stands, deck clearance, and pool curb do not meet appropriate operational and safety standards
- Water collects at multiple locations on the pool deck




Limited
Deck
Space

Spectator seating not
ADA compliant

Limited
Deck
Space







Natatorium/Pool:

- Piping tunnel around circumference of the pool showed significant evidence of leakage from the pool
- Water damage has caused significant spalled concrete and exposed heavily rusted steel reinforcing bars
- Filtration and chemical systems exhibit multiple operational and safety issues

